



**DRDL**

**Hyderabad**

# **5<sup>th</sup> Prof. P. J. Paul Memorial Combustion Researchers' Meet**

**February 23-24, 2018**

**A study on the approach to reduce wind effects through porous wall configuration for indoor pool fire tests**

**Bhaskar Dixit, Manasa Murugesh**

**Fire & Combustion Research Center  
Jain University  
Jakkasandra 562 112**



# Content

- Background
- Jain Fire Lab
- Small Pool – Experiments
- FDS – Porous wall facility
- Summary

# Background

- Fire testing fire suppression products – carried out globally indoors and outdoors
- Outdoor testing – susceptible to ambient winds – Test protocols limit winds to  $< 2$  m/s
- Typically Indoor configurations are mechanically ventilated – difficult, leads to excruciating conditions indoors - fire behaviors different from outdoors
- Experiments to provide a design basis for porous wall structure & computations of the indoor flow field will be presented

# Fire Test Facility UL North Brook, USA

## Mechanical Exhaust



**UL standards Fire Test Facility - 18 x 12 x 6.6 m high**  
**Mechanical Ventilation - Moving away dirt hot gases at the top; if inadequate, will fill the room & smoke descends causing operational problems, huge blowers needed**  
**Total 12 m<sup>3</sup>/s Air supplied to 4 corners**  
**Total blower power estimated - 250 kWe**

# Jain Fire Lab

- Built with double staggered porous wall structure
- Indoor fire tests carried out by UL have met with standard requirements for indoor conditions for large fire tests





20 B test





# Jain Fire Lab

- Simultaneous measurements of wind inside & outside fire lab
- It is seen that indoor velocities are very low and the environment inside qualifies to be 'indoor' condition





# Indoor Fire Lab Roof T Data



- A 20 min diesel pool fire was run to evaluate performance
- Min smoke emitting height was seen to be 7 m
- Roof wall temperature attained is acceptable to the design

# Fire Tests with Small Pans

- Existing porous wall configuration adequate for large pool fires
- Smaller pan fires were found to be susceptible low ambient disturbances
- Bottom 3 layers of Fire lab closed as shown
- This has resulted in undisturbed small pan fires




Porous Restriction  
in Bottom Region





# Small Pool Experiments

- A double walled porous 4 m Sq x 0.8 m high - created at the center of the fire lab with annular gap of 0.2 m
- Indoor conditions monitored using anemometers with steady wind of about 2 m/s provided using a Pedestal fan
- 500 mm dia pan fire tested in this configuration




# Small Pool-Experiments


- Cold flow measurements with 2 m/s wind generated by fan shown
- Measurements indicate inside velocities  $< 0.3$  m/s



# Small pools - Experiments



Still ambient




2 m/s (Fan Velocity)

Work is in progress to carry out experiments with Different levels of porosity for smaller pool sizes to eliminate random wind effects





# FDS – Porous Wall Facility

- FDS used as a tool during Jain fire lab development
- Initially effect of solid North was computed to quantify its influence
- Studies have indicated marginal increase in flow rates
- Fire behaviour was also compared with literature results as shown next..




# Literature Comparisons



FDS H & V profiles along 12 m side for porous & solid North shown


PIV meas. & simul of 1m  $CH_4$  pool fire Xin et. al: 2008



# FDS – Porous Wall Facility

18.3 m x 12.2 x  
12.2 m high, 3 m  
sq chimney  
Calculations with  
refined mesh (0.1  
m Sq) in fire  
region – 4 m width  
(X & Y)



Mesh size: 100  
mm in fire region  
150 mm else  
where  
(3.2 million cells)











# Boundary Conditions

- Calculations performed:
  - JFL – Fuel: 72 g/m<sup>2</sup>s
  - Open pool fire: 72 g/m<sup>2</sup>s
  - Ramped Flux (up to 65% by 1<sup>st</sup> min)
  - Still & Windy Boundaries
  - JFL - Restricted bottom region
- End time of all calculations - 90 s



# JFL – 72 g/m<sup>2</sup>s




- Mdot increase with amb T -> Buoyancy; Stabilize by ~90 s



# JFL –


## Mass Flow Rates

- 41 - 50 s average flow rates compared
- JFL indoor flows comparable till 7 m height beyond which, indoor flows fall due to roof effects
- Additional restriction in bottom zone has resulted in small changes
- Mass flow rate plateaus seen to coincide with S,W & E wall blockages





# JFL: Wind Effects

- Calculations with wind has shown about 5% increase in side flow fraction for imposed ambient wind of  $\sim 0.8$  m/s
- 60% lower fire power has resulted in  $\sim 11\%$  lower peak  $\dot{m}_{dot}$  during averaged 41 – 50 s period for still air
- Wind has contributed to  $\sim 5\%$  increase in peak  $\dot{m}_{dot}$





Wind: 70 -80 s

Still  
Ambient  
70-80 s



direction  
←

# Porous Wall: Smoke Egress



- East, South & West sides of porous wall simultaneously videoed
- Windy ambient outdoors: velocities exceeding 2 m/s
- Smoke egress seen first at ~11 s through west wall and 8 s through south wall - coincides with calculations

# Summary

- Minimizing ambient wind disturbances in fire tests discussed
- Effect of wall pore size on smaller fire appears significant during random wind events
- Studies focus on minimizing this effect by suitably reducing pore size
- Studies are in progress to provide a scientific basis for selection of nature of porosity





Thank You